

Report No.: 1

Test Time: 13.12.2017 10:40

Luminaire Property

Luminaire Manufacturer: FAROS

Luminaire Description: FP 150 100W 5000K 2x40-100gr. NEMA

Number of Lamps: 1

Luminous Width (mm): 153

Voltage: 231.6 V

Power: 93.44 W

Luminous Length (mm): 496

Luminous Height (mm): 80

Current: 0.415 A

Power Factor: 0.970

Photometric Results

CIE Class: Direct

Measurement Flux: 11236.1 lm

Downward Ratio: 100%

Field Angle(C0/C180,C90/C270,C45/C225,C135/315): 119.2, 135.3, 136.0, 135.2

Beam Angle(C0/C180,C90/C270,C45/C225,C135/315): 103.7, 115.1, 119.8, 119.5

Luminaire Efficacy Rating (LER): 120.30

Max. Intensity: 5394.63 cd

S/MH(C0/C180): 2.39

Total Rated Lamp Lumens: 11236.1 lm

Efficiency: 100%


Upward Ratio: 0%

Central Intensity: 1742.07 cd


Pos of Max. Intensity: H180 V38

S/MH(C90/C270): 1.92

Picture Of Luminaire



Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 22.5

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-180.0:2.0



Test Device: LSG-1800B

Distance: 12.606 m

Humidity:

Inspector:


Luminous Intensity Distribution Curve



C Plane (°):0.0-360.0: 22.5
 Test Lab:
 Test Type: TYPE C
 Temperature:
 Operator:



Gamma Plane (°):0.0-180.0:2.0
 Test Device: LSG-1800B
 Distance: 12.606 m
 Humidity:
 Inspector:

Luminous Intensity Distribution Curve(cd/klm)



Lum Limit Curve

Dazzle	Quality	Illuminance (lx)							
		a	b	c	d	e	f	g	h
1.15	A	2000	1000	500	<=300				
1.50	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.20	D				2000	1000	500	<=300	
2.55	E					2000	1000	500	<=300



L(cd/sq.m)	G45	G50	G55	G60	G65	G70	G75	G80	G85
C0	55742	41201	19923	6160	2626	1706	1169	778	463
C90	35515	33950	28383	19512	9114	3922	3664	3092	1529
C180	57776	43445	22047	7200	2960	1821	1294	866	553
C270	38111	35516	30052	21165	11106	4663	3933	3702	2031

C Plane (°):0.0-360.0: 22.5

Test Lab:

Test Type: TYPE C

Temperature:

Operator:

Gamma Plane (°):0.0-180.0:2.0


Test Device: LSG-1800B

Distance: 12.606 m

Humidity:

Inspector:

Illuminance at a Distance



UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	25.1	26.4	25.4	26.6	26.9	25.3	26.6	25.6	26.9	27.1
3H	24.9	26.1	25.2	26.4	26.7	25.3	26.5	25.6	26.8	27.0
4H	24.8	26.0	25.2	26.2	26.6	25.2	26.4	25.6	26.6	26.9
6H	24.8	25.8	25.1	26.1	26.4	25.2	26.2	25.5	26.5	26.8
8H	24.7	25.7	25.1	26.0	26.4	25.1	26.1	25.5	26.5	26.8
12H	24.7	25.6	25.1	26.0	26.3	25.1	26.1	25.5	26.4	26.7
X=4H Y=2H	25.4	26.5	25.8	26.8	27.1	25.6	26.7	26.0	27.0	27.3
3H	25.3	26.2	25.7	26.6	26.9	25.6	26.6	26.0	26.9	27.3
4H	25.2	26.1	25.6	26.4	26.8	25.6	26.4	26.0	26.8	27.2
6H	25.2	25.9	25.6	26.3	26.7	25.5	26.3	26.0	26.7	27.1
8H	25.1	25.8	25.6	26.2	26.6	25.5	26.2	26.0	26.6	27.0
12H	25.1	25.7	25.6	26.1	26.6	25.5	26.1	26.0	26.5	27.0
X=8H Y=4H	25.1	25.8	25.6	26.2	26.6	25.5	26.2	25.9	26.6	27.0
6H	25.1	25.6	25.6	26.1	26.5	25.5	26.0	25.9	26.4	26.9
8H	25.1	25.5	25.5	26.0	26.5	25.4	25.9	25.9	26.4	26.9
12H	25.0	25.4	25.5	25.9	26.4	25.4	25.8	25.9	26.3	26.8
X=12H Y=4H	25.1	25.7	25.6	26.1	26.6	25.5	26.1	25.9	26.5	26.9
6H	25.1	25.5	25.5	26.0	26.5	25.4	25.9	25.9	26.4	26.8
8H	25.0	25.4	25.5	25.9	26.4	25.4	25.8	25.9	26.3	26.8
Variations with the observer position at spacings:										
S=1.0H	+1.2/-1.9					+0.5/-0.6				
S=1.5H	+2.7/-9.6					+2.5/-4.2				
S=2.0H	+3.6/-13.2					+3.4/-8.1				

Calculate in accordance with CIE Pub.117. The table is revised with $11236lm$ ($8\log(F/F_0) = 8.4$).

Utilisation Factor Table(Floor cavity)

Utilisation Factors UF(F)			SHR NOM = 2.00									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	NA	0.80	0.85	0.90	0.96	1.00	1.02	1.05	1.08	
	0.30		NA	0.74	0.80	0.85	0.92	0.96	0.99	1.03	1.05	
	0.20		NA	0.70	0.76	0.81	0.88	0.93	0.96	1.00	1.03	
0.50	0.50	0.20	NA	0.78	0.83	0.87	0.93	0.97	0.99	1.02	1.03	
	0.30		NA	0.73	0.78	0.83	0.89	0.93	0.96	0.99	1.01	
	0.20		NA	0.69	0.75	0.79	0.86	0.91	0.93	0.97	1.00	
0.30	0.50	0.20	NA	0.76	0.81	0.85	0.90	0.93	0.95	0.98	1.00	
	0.30		NA	0.72	0.77	0.81	0.87	0.91	0.93	0.96	0.98	
	0.20		NA	0.68	0.74	0.78	0.85	0.88	0.91	0.94	0.96	
0.00	0.00	0.00	NA	0.66	0.71	0.75	0.81	0.85	0.87	0.90	0.92	
<p>Rating:93W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980</p>												

Utilisation Factor Table(Wall)

Utilisation Factors UF(W)			SHR NOM = 2.00									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	NA	0.62	0.53	0.45	0.35	0.28	0.24	0.19	0.15	
	0.30		NA	0.53	0.46	0.40	0.31	0.26	0.22	0.17	0.14	
	0.20		NA	0.47	0.41	0.36	0.29	0.24	0.21	0.16	0.14	
0.50	0.50	0.20	NA	0.59	0.50	0.43	0.33	0.30	0.23	0.17	0.14	
	0.30		NA	0.52	0.44	0.38	0.30	0.25	0.21	0.16	0.13	
	0.20		NA	0.46	0.40	0.35	0.28	0.23	0.20	0.16	0.13	
0.30	0.50	0.20	NA	0.57	0.48	0.41	0.31	0.25	0.21	0.16	0.13	
	0.30		NA	0.50	0.43	0.37	0.28	0.23	0.20	0.15	0.13	
	0.20		NA	0.45	0.39	0.34	0.26	0.22	0.19	0.15	0.12	
0.00	0.00	0.00	0.99	0.33	0.28	0.24	0.18	0.15	0.12	0.09	0.08	
<p>Rating:93W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980</p>												

Utilisation Factor Table(Ceiling cavity)

Utilisation Factors UF(C)			SHR NOM = 2.00									
Room Reflectance			Room Index(RI)									
Ceiling	Wall	Floor	0.75	1.00	1.25	1.50	2.00	2.50	3.00	4.00	5.00	
0.70	0.50	0.20	NA	0.16	0.17	0.18	0.19	0.20	0.20	0.21	0.21	
	0.30		NA	0.11	0.13	0.14	0.16	0.17	0.18	0.19	0.20	
	0.20		NA	0.08	0.09	0.11	0.13	0.14	0.15	0.17	0.18	
0.50	0.50	0.20	NA	0.16	0.17	0.17	0.18	0.19	0.19	0.20	0.21	
	0.30		NA	0.11	0.12	0.13	0.15	0.16	0.17	0.18	0.19	
	0.20		NA	0.07	0.09	0.10	0.12	0.14	0.15	0.16	0.17	
0.30	0.50	0.20	NA	0.15	0.16	0.17	0.18	0.18	0.19	0.19	0.20	
	0.30		NA	0.11	0.12	0.13	0.15	0.16	0.17	0.18	0.18	
	0.20		NA	0.07	0.09	0.10	0.12	0.14	0.15	0.16	0.17	
0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
<p>Rating:93W Photometrically tested without ceiling board. Multiply UF values by service correction factors Calculate in accordance with CIBSE Technical Memorandum NO.5 1980</p>												